




State of Ohio Environmental Protection Agency

Northeast District Office

2110 E. Aurora Road
Twinsburg, Ohio 44087-1969
(216) 425-9171



Richard F. Celeste
Governor

July 13, 1989

RE: NPDES PERMIT NO. 3ID00021*DD
OH0004219

Mr. William Lacure
Environmental Control Coordinator
The Timken Company
1835 Dueber Avenue
Canton, Ohio 44706

Dear Mr. Lacure:

We are in receipt of your letter dated June 7, 1989, which informs us of certain instances of noncompliance with the NPDES permit conditions during the month of May. The specific instances of noncompliance are noted below:

<u>DATE</u>	<u>OUTFALL</u>	<u>PARAMETER</u>	<u>REPORTED VALUE</u>	<u>PERMIT LIMIT</u>
5/30/89	007	pH	12.3 S.U.	9.0 S.U. (max)
5/01/89	015	Zinc	856 ug/l	365 ug/l (max)
5/01/89	015	Zinc	14.12 kg/day	9.97 kg/day (max)
5/01/89	017	pH	9.6 S.U.	9.0 S.U. (max)

Please be advised that such instances of noncompliance may be cause for further enforcement action pursuant to the Ohio Revised Code, Chapter 6111.

If you have any questions regarding the above, please contact the writer at (216) 425-9171.

Yours truly,

Kelvin F. Rogers
Environmental Scientist
Division of Water Pollution Control

KFR:mjo

cc: Bob Phelps, DWPC, CO